

Certificate of Conformity

Certificate Number: 180903078GZU-001

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. This certificate is part of the full test report<s> and should be read in conjunction with it;

Applicant Name & Address: Shenzhen SOFAR SOLAR Co., Ltd.

5/F, Building 4, Antongda Industrial Park, No.1 Liuxian Avenue. Xin'an Street,

Bao'an District, Shenzhen, P.R, China

Product Description: Hybrid Inverter

Ratings & Principle See Annex to Certificate of Conformity

Characteristics:

Models:

HYD 4000-ES, HYD 5000-ES, HYD 6000-ES

Relevant Standards ER G59, issue 3 Amendment 3 February 2018

Recommendations for the connection of generating Plant to the distribution systems of licensed distribution

Network operators

Certificate Issuing Office: Same as Intertek Legal Entity

Date of Tests: 03 Sep 2018 – 07 Sep 2018

Test Report Number(s): 180903078GZU-001

Additional information in Appendix.

Signature

Name: Grady Ye Position: Manager

Issuing Office: Intertek Legal Entity: Intertek

/ suste @intertek

Testing Services Shenzhen Ltd.

Guangzhou Branch

Date: 11 Sep 2018

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Certificate are relevant only to the sample tested/inspected. This Certificate by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.



APPENDIX: Certificate of Conformity

This is an Annex to Certificate of Conformity with Certificate/Report Number(s): 180903078GZU-001; The issuing office is Intertek Legal Entity as above.

Ratings and principal characteristics

Max. DC Input Voltage: 600Vdc

Operating MPPT Voltage Range: 90Vdc - 580Vdc

Max. PV Isc: 2 X 15A

Battery Type: Lead-acid, Lithium-ion

Battery Voltage Range: 42-58V
Max. Charging Current: 65A
Max. Discharging Current: 70A

Max. Charging & Discharging Power: 3000VA

Nominal Grid voltage: 230Vac

Nominal Output Voltage (backup): 230Vac

Max. output current: 18.2A (for HYD 4000-ES), 22.8A (for HYD 5000-ES),

27.3A (for HYD 6000-ES),

Nominal Grid Frequency: 50Hz

Power Factor: 1 (adjustable +/-0.8)

Nominal output power: 4000VA (for HYD 4000-ES), 5000VA (for HYD 5000-ES), 6000VA (for HYD

6000-ES),

Backup Rated current: 13.2A

Backup Rated Apparent Power: 3000VA

Ingress Protection: IP 65

Protective Class: I

Operating temperature range: -25 — +60°C

Software version: V1.00